

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 375

Dated: 10/5/2021

FIRE SAFETY CERTIFICATE

Certified that the KIIT World School (New State Academy Sr. Secondary School), located at Zone H-4, Pitampura, Delhi-110034, consists of Two Blocks : BL-1 comprised of Ground + 03 Upper Floors & BL-2 comprised of Ground Floor only were issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2018/394 dated 12.03.2018 & F6/DFS/MS/SCHOOL/2018/1020 Dated 10.05.2018 respectively. The said premises were re inspected by the officer concerned of this department on 06.04.2021 in the presence of Dr. Sangeeta Bhatia (Vice-Principal) & Ms. Richa Verma (Head Mistress) and found that the premises / buildings have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and found that the premises/building is fit for occupancy "Educational" Group B with effect from 10/5/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/5/21 at New Delhi by,

  
(Dharampal Bhatia)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi - 110054.
2. The Principal, KIIT World School, Zone H-4, Pitampura, New Delhi-110034.

CONDITIONS

1. A Porta Cabin on Terrace shall not be used for School Activities, else FSC shall be null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

  
KIIT WORLD SCHOOL  
Zone H-4, Pitampura, Delhi